

批核及驗收程序

DEE – 屋宇結構廳	
屋宇配水管 – uPVC 管及配件	文件編號：ARP/DEE/013
	修改號：A
	日期：2021/03/31
	頁碼：1 of 4

1 參考規範

第 46/96/M 號法令	澳門供排水規章
AS/NZS 4020:2005	Testing of products for use in contact with drinking water
BS 3505:1986	Specification for unplasticized polyvinyl chloride (PVC-U) pressure pipes for cold potable water
BS 6920-1:2014	Suitability of non-metallic materials and products for use in contact with water intended for human consumption with regard to their effect on the quality of the water. Specification
BS EN ISO 1452-1:2009	Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure. Unplasticized poly(vinyl chloride) (PVC U). General
BS EN ISO 1452-2:2009	Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure. Unplasticized poly(vinyl chloride) (PVC U). Pipes
BS EN ISO 1452-3:2010	Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure. Unplasticized poly(vinyl chloride) (PVC U). Fittings
BS EN ISO 1452-4:2009	Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure. Unplasticized poly(vinyl chloride) (PVC U). Valves
BS EN ISO 1452-5:2009	Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure. Unplasticized poly(vinyl chloride) (PVC U). Fitness for purpose of the system
GB 5749:2006	生活飲用水衛生標準
GB/T 17219:1998	生活飲用水輸配水設備及防護材料的安全性評價標準
GB/T 10002.1:2006	給水用硬聚氯乙烯(PVC-U)管材
GB/T 10002.2:2003	給水用硬聚氯乙烯(PVC-U)管件

批核及驗收程序

DEE – 屋宇結構廳	
屋宇配水管 – uPVC 管及配件	文件編號：ARP/DEE/013
	修改號：A
	日期：2021/03/31
	頁碼：2 of 4

2 審核程序

所有材料（管材、配件、喉箍、黏合劑等）事前需進行審核，審核需提交以下文件，包括：

- 產品說明書；
- 檢測報告或相關認可文件；
- 施工方案；
- 如有需要確認工廠的技術和品質能滿足工程要求，將根據實際情況對工廠進行視察。

2.1 產品說明書

1. 應最少包含但不限於以下的內容：

項目	內容
基本參數	如：產品生產的參考標準、管徑、壁厚等
力學性能	如：抗拉強度、抗壓強度、抗衝擊性能等
水密性能	如：最大工作壓力等
耐熱性能	如：維卡軟化溫度等
施工指引	如：保存方法、運送方法、安裝方法及安裝所需設備等

2. 除非工程設計有規定，所提交之材料應符合參考規範之要求。

2.2 檢測報告或相關認可文件

1. 提交有效的檢測報告或認可文件，若相關文件沒有指明有效日期，建議提交最近三年發出的文件。
2. 檢測報告的檢測內容應包含但不限於以下內容：

項目	內容
基本參數	如：產品標示、管徑、壁厚、外觀等
力學性能	如：拉伸性能、落錘衝擊等
水密性能	如：水壓試驗等
耐熱性能	如：維卡軟化溫度等

一般情況下，檢測報告的參考標準應與產品的生產標準一致。

批核及驗收程序

DEE – 屋宇結構廳	
屋宇配水管 – uPVC 管及配件	文件編號：ARP/DEE/013
	修改號：A
	日期：2021/03/31
	頁碼：3 of 4

3. 檢測報告或認可文件需要由第三方機構發出。
4. 若安裝之管道用於飲用水，管道的所有材料(例如：管材、黏合劑等)需要提交可用於飲用水的有效證明文件，以證明材料符合 AS/NZS 4020、GB/T 17219、BS 6920(只限非金屬)或其他等效標準的要求，確保物料滿足相關標準有關細菌、重金屬、化學及物理等參數的要求。若相關文件沒有指明有效日期，建議提交最近三年發出的文件。

2.3 施工方案

施工方案需符合澳門供排水規章及設計單位的要求，同時亦應按照產品生產商的施工指引，其內容需說明材料的運送、保存、安裝、清潔等。

3 驗收程序

3.1 現場驗收

承建商需呈交製造商發出之來源證及供應商發出之發貨單。

現場到貨的物料應外觀完好且有清晰的標示，內容應包括：牌子、參考標準、尺寸、級別等。

3.2 管材測試

檢測項目	檢測頻率	合格準則
尺寸檢查	每批次為 50 噸； 同一尺寸、同一原料、同一工藝和同一規格生產的管材作為一批	按產品標準
維卡軟化溫度		
縱向回縮率		
拉伸性能		
落錘沖擊		
液壓試驗		
二氯甲烷浸漬試驗	如有需要	

批核及驗收程序

DEE – 屋宇結構廳	
屋宇配水管 – uPVC 管及配件	文件編號： ARP/DEE/013
	修改號： A
	日期： 2021/03/31
	頁碼： 4 of 4

3.3 現場測試

所有管段於安裝後，應按照澳門供排水規章第 191 條進行不漏測試。

3.4 水質驗收

總供水系統進行沖洗後，應按 ARP/DEE/018 進行水樣本測試。