

Approval & Reception Procedure

DEE – Departamento de Estruturas e Edifícios	
Building Water Distribution System – Non-alloy steel Pipes and Accessories	Document No.: ARP/DEE/021
	Rev. No.: A
	Date: 2022/01/31
	Page No.: 1 of 4

1 Reference standard

Regulations No. 46/96/M	Regulamento de Águas e de Drenagem de Águas Residuais de Macau (RADARM)
AS/NZS 4020:2005	Testing of products for use in contact with drinking water
BS 6920-1:2014	Suitability of non-metallic materials and products for use in contact with water intended for human consumption with regard to their effect on the quality of the water. Specification
BS EN 10255:2004	Non-alloy steel tubes suitable for welding and threading. Technical delivery conditions
GB 5749:2006	Standards for Drinking Water Quality
GB/T 17219:1998	Standard for safety evaluation of equipment and protective materials in drinking water system
GB/T 3091:2015	Welded steel pipes for low pressure liquid delivery

2 Approval procedures

All materials (pipes, fittings/accessories, exterior coatings, interior linings, joints, sealing tapes, insulation material, etc) are required to be approved in advance, and the following documents should be submitted for the approval:

- Products specification
- Test reports or related recognized documents
- Method statements
- Depending on the actual situation, inspections on the factory will be required to verify the technical and quality competence for the project

2.1 Product specification

1. Product specification should include at least but not limited to the following content :

Approval & Reception Procedure

DEE – Departamento de Estruturas e Edifícios	
Building Water Distribution System – Non-alloy steel Pipes and Accessories	Document No.: ARP/DEE/021
	Rev. No.: A
	Date: 2022/01/31
	Page No.: 2 of 4

Items	Content
General Parameters	Reference standards for product manufacture, dimensions, diameter, wall thickness, composition and thickness of exterior coatings and interior linings, etc
Mechanical Properties	Product grade, tensile strength, compressive strength, etc
Water-tightness Properties	Maximum working pressure, etc
Chemical Composition	The content of carbon, manganese, sulfur, phosphorus, etc
Construction Guidelines	Storage, transportation, installation method and equipment required for installation, etc

- Unless otherwise specified in the project design, the submitted materials should comply with the requirements of the reference standard.

2.2 Test reports or related recognized documents

- Test reports or certification documents should be issued by third-party organization.
- Test reports or certification documents should be valid. If the relevant documents have not specified the effective date, it is advisable to submit the documents issued in recent three years.
- The test content of the test reports should include but not limited to the following :

Items	Content
General Parameters	Marking, diameter, wall thickness, appearance, thickness of exterior coatings and interior linings, etc
Mechanical Properties	Tensile test, bending test, hardness test, etc
Water-tightness Properties	Water-tightness tests, etc
Chemical Composition	Chemical composition of material, etc

In general, the reference standards of the test reports should be consistent with the reference standards for product manufacture.

Approval & Reception Procedure

DEE – Departamento de Estruturas e Edifícios	
Building Water Distribution System – Non-alloy steel Pipes and Accessories	Document No.: ARP/DEE/021
	Rev. No.: A
	Date: 2022/01/31
	Page No.: 3 of 4

4. If the installed pipelines are used for drinking water, the pipelines should have suitable interior linings, and valid certification documents that can be used for drinking water should be submitted for all materials of the pipelines (such as pipes, fittings/accessories, materials of interior linings, etc.), to ensure that the materials comply with AS/NZS 4020, GB/T 17219, BS 6920 (only for non-metal) or other equivalent standards, in order to ensure that the materials comply with the requirement of relevant standards in parameters of bacteria, heavy metals, chemical and physical, etc. If the relevant documents have not specified the effective date, it is advisable to submit the documents issued in recent three years.

2.3 Method statements

The method statements should comply with the requirements of RADARM and the designer, and should follow the construction guidelines of the product manufacturers. The contents of the method statements should state the transportation, storage, installation and cleaning, etc, of the materials.

3 Reception procedure

3.1 On-site acceptance

1. The contractor should submit mill certificates issued by the material manufacturers and the delivery note issued by the suppliers.
2. The materials delivered on-site should be good in appearance and clearly marked. The content should include: brand, reference standard, dimension, grade, etc.
3. The coating uniformity test, tensile strength test and dimension test should be performed in accordance with APR/DMC/06.

3.2 Field tests

After installation, water-tightness tests should be performed in accordance with Article 191 of RADARM in all pipe sections.

Approval & Reception Procedure

DEE – Departamento de Estruturas e Edifícios	
Building Water Distribution System – Non-alloy steel Pipes and Accessories	Document No.: ARP/DEE/021
	Rev. No.: A
	Date: 2022/01/31
	Page No.: 4 of 4

3.3 Water Quality Testing

After flushing of the main water supply system, water quality testing should be performed in accordance with ARP/DEE/018.